

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0559:0166

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: SILENT KNIGHT SECURITY, 7550 Meridian Circle, Maple Grove, MN, 55369-4927
Contact: Michael McIsaac (763) 463-4144 Fax (763) 493-6475
Email: mike.mcisaac@honeywell.com

DESIGN: Models 5824 Serial/Parallel Interface Module, 5880 LED IO Module and 5883 Relay Interface Board. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control unit accessories for use with separately listed compatible fire alarm control panels.

04-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **April 09, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division